



**SOLVAY
MINERALS**

January 27, 2004



Dan Olson
WDEQ-Air Quality Division
122 W. 25th Street
Cheyenne, WY 82002

RE: Permit 30-126 Condition (F10) Annual Compliance Test on AQD #17

Dear Dan:

Permit 30-126 Condition F(10) requires annual compliance testing for NO_x emissions on AQD #17, the common stack for "A" and "B" Calciners. The testing was conducted November 18, 2003. The test report, as well as certification by Ronald O. Hughes, Resident Manager, is enclosed.

EPA Reference Method 7 was utilized, resulting in an emission rate of 23.8 pph NO_x. This demonstrates compliance within the permit limit of 30.0 pph.

If you have any questions concerning the test report, please contact me at (307) 872-6571.

Respectfully submitted,

Dolly A. Potter / TAB

Dolly A. Potter
Environmental Services Supervisor

Enclosure

cc: Tony Hoyt